

Development and Evaluation of an Intelligent Control System for Sustainable and Efficient Energy Management

BIBARS AMANGELDY *, NURDAULET TASMURZAYEV, YEDIL NURAKHOV,
SHONA SHINASSYLOV, SAMSON DAWIT BEKELE
Joldasbekov Institute of Mechanics and Engineering,
Building 2, Shevchenko Street, Medeusky District, Almaty,
KAZAKHSTAN

**Corresponding Author*

Abstract: - This paper presents a comprehensive study on the integration of Intelligent Control Systems in the global industrial sector, focusing on enhancing energy management through the synergy of Supervisory Control and Data Acquisition (SCADA), Machine Learning (ML), and Digital Twin technologies. We elaborate on a novel ICS architecture designed to optimize energy consumption, reduce operational costs, and minimize environmental impacts. Our system leverages SCADA for real-time monitoring and control, ML algorithms for predictive analytics and optimization, and Digital Twin technology for advanced simulation and operational efficiency. The implementation of the system in a mid-scale industrial facility demonstrated significant improvements: a 15% reduction in energy consumption, an 18% decrease in peak energy demand, a 30% reduction in CO₂ emissions, and a 15% reduction in operational downtime, with predictive accuracy standing at 90%. These results underline the potential of integrating advanced digital technologies in industrial energy management, offering a scalable model for sustainable and efficient industrial practices. Future work will explore broader applications and the incorporation of emerging technologies to further enhance the system's capabilities and applicability in diverse industrial settings.

Key-Words: - Intelligent Control System, Machine Learning, Digital Twin, SCADA, Energy Efficiency, Operational Efficiency, Real-Time Control.

Received: March 18, 2023. Revised: October 21, 2023. Accepted: December 2, 2023. Published: December 31, 2023.

1 Introduction

The global industrial sector is at the cusp of a technological revolution, driven by the integration of Intelligent Control Systems (ICS) for energy management. The primary objective is to harness modern technologies to optimize energy consumption, reduce operational costs, and minimize environmental impact. Among the technologies spearheading this transformation are Supervisory Control and Data Acquisition (SCADA), Machine Learning, and Digital Twin.

SCADA: SCADA systems are instrumental in the real-time monitoring and control of industrial processes. They have evolved with technological advancements to collaborate with microprocessors wirelessly, collecting measurements from distant locations, thereby augmenting the efficiency and sustainability of energy management systems, [1], [2]. For instance, a novel energy management architecture model based on a comprehensive SCADA system has been implemented in an educational building, showcasing the potential of

SCADA in modern energy management systems, [3].

Machine Learning (ML): ML algorithms are pivotal in scrutinizing the extensive data generated by industrial processes to forecast future energy demands, pinpoint potential issues, and optimize energy consumption, [4]. The application of ML in energy management extends to creating models for predicting energy consumption and proposing architectures for intelligent energy management systems, especially in the public sector, [5]. Moreover, the integration of ML with renewable energy sources and smart grids fosters a sustainable solution to energy demand management challenges, [6].

Digital Twin: Digital Twin technology has emerged as a significant catalyst for realizing step-improvements in energy management and optimization. It facilitates the creation of a virtual representation of the physical system, enabling real-time monitoring, superior servicing and maintenance, energy-efficient design evolution, and

integration with locally and regionally generated renewable energy, [7], [8], [9]. For instance, the digital twin technology in the energy industry allows for the development and sustenance of intelligent networks enriched with high-tech sensors and machine learning models, thereby enhancing performance monitoring, [10].

The fusion of SCADA, ML, and Digital Twin technologies fabricates a robust framework for an ICS directed towards sustainable and efficient energy management. This paper elucidates the architecture and evaluation of such a system, underscoring its effectiveness in ameliorating energy efficiency and sustainability in real-world scenarios.

The ensuing sections will delve into the elaborate architecture of the proposed system and present the results emanating from its implementation, showcasing the potential of these integrated technologies in revolutionizing energy management practices within the industrial sector.

2 Architecture of the System

The architecture of the proposed intelligent control system is designed to facilitate sustainable and efficient energy management by integrating SCADA, ML, and Digital Twin technologies. The detailed architecture of the system can be seen in Figure A1 in Appendix. For a detailed view of the communication and control architecture, which highlights the synergy between various communication protocols, machine learning models, and external platform integrations, refer to Figure A2 in Appendix. The intricacies of the system's architecture are elaborated in the following subsections, with specific components and their functions referenced according to their depiction in Figure A1 in Appendix.

2.1 Physical Layout

At the system's physical core, there are:

Environmental Sensors: Instruments like absolute pressure (18), temperature (20), and humidity sensors (21) form the primary line of defense. By constantly monitoring ambient conditions, these sensors ensure that operations are kept within specified parameters. Their integration guarantees a stable environment and prevents potential hazards that could arise from system anomalies.

Gas Concentration Sensors (39): These sensors, focused on gases like CH₄, CO₂, and PM_{2.5}, act as watchdogs in environments

susceptible to gas leaks or harmful emissions.

These sensors are fundamental for monitoring and ensuring environmental safety within operational parameters, echoing recent trends in employing sensor technologies for real-time monitoring in energy systems.

Mechanical Components (6): Essential machinery such as compressors, heaters, and electromagnetic valves are integrated to uphold the system's operational integrity. These components are central to maintaining appropriate fluid or gas flow rates and ensuring that the system responds effectively to the inputs from the sensors. Figure 1 is the installation view.



Fig. 1: Installation

2.2 Control Panel

The control panel serves as the user's gateway to the system:

PLC Interface: Serving as the bridge between the physical and digital realms, the PLC facilitates both data acquisition and transmission.

Digital Interface: It offers an intuitive interface, displaying real-time metrics and system insights. Users can either manually tune system settings or oversee automatic operations, making it adaptable to both hands-on and hands-off approaches. The design of the control box can be seen in Figure 2.

Actuation Units: These units, which manage the valves, compressors, and similar machinery, provide the system with its responsive nature. They ensure that the mechanical components are orchestrated harmoniously, in line with sensor inputs.




Fig. 2: Design of the control box

2.3 Communication Backbone

The seamless communication between physical systems and their digital twins is crucial for ensuring real-time measurements and data accuracy, [11]. By leveraging multiple protocols, the system ensures that data flows without hindrance:

OPC UA (31): In our system, OPC UA is employed for its high security and reliability, especially in facilitating the real-time transfer of operational data from sensors to our central processing unit. This is crucial for our system's ability to make timely adjustments in response to environmental changes.

Modbus TCP (32): As a universal protocol, Modbus TCP is used for its versatility in connecting various electronic units within the system. It plays a key role in ensuring the smooth exchange of operational data between different components like sensors, actuators, and the control panel.

RS-485 (15): With its robust design, RS-485 is utilized in our expansive plant layout, offering reliable point-to-point and multipoint communication over long distances. This is essential for maintaining a robust data communication network throughout our facility.

Wi-Fi TCP/IP & Controller (26): Wi-Fi TCP/IP enables remote monitoring and management of the system, allowing for off-site control and observation. The controller, developed in C++, enhances this by efficiently processing data and sending commands back to the system, facilitating real-time decision-making and system adjustments.

The control and data acquisition module can be seen in Figure 3.




Fig. 3: Control and data acquisition module

2.4 Data Processing & Predictive Analytics (33-36)

Machine Learning Integration: Utilizing XGBoost and Random Forest algorithms, the system can predict potential system failures, optimize operations, or suggest maintenance schedules. They also optimize energy consumption by analyzing patterns and suggesting adjustments to reduce waste.

Forecasting: Predictive analytics also play a pivotal role in forecasting future conditions, allowing the system to adapt proactively to changing energy demands and environmental conditions.

Decision-Making Engine: Based on the incoming data and predictions, the decision-making engine either automates critical adjustments or provides operators with data-driven recommendations. This integration not only enhances operational efficiency but also significantly contributes to our overarching objective of developing a more sustainable, energy-efficient industrial environment.

The integration of IoT, AI, and ML facilitates predictive analytics and intelligent decision-making, optimizing operations and suggesting maintenance schedules, [12].

2.5 Integration with Other Platforms

Digital Assistants: Voice-driven platforms like Google Home, Telegram Bot, Apple Home, and Yandex Alice are integrated to offer users an alternative interaction method.

SCADA Integration: For expansive industrial operations, the bird's eye perspective provided by

SCADA is invaluable. It aids in holistic process monitoring and promotes safety, [13]

Web and Database Systems: Web interaction, powered by a Node.js server with a Python Flask API, lets users remotely access system insights or modify parameters. Meanwhile, the SQL database integration ensures data longevity, paving the way for long-term analytics and report generation.

Digital Twin Integration: The integration of digital twin technology serves as a cornerstone for achieving a seamless interaction between our system and external platforms. Digital twins provide a dynamic, real-time representation of the system, aiding in both monitoring and control. The utilization of smart digital twins supports decision-making on the development of intelligent integrated energy systems and subsequent management, emphasizing the importance of automation, informatization, and digitalization as prerequisites for the intellectualization of energy systems, [14]. This integration facilitates a more comprehensive understanding and control over the system, enhancing our ability to interact with other platforms such as SCADA, ML algorithms, and external digital assistants.

3 Results

The ICS was implemented in a mid-scale industrial facility. The conceptual design of the control box, as illustrated in Figure 2, is realized and depicted in Figure 4, showcasing the actual setup of the control box in use. The results were evaluated based on three major criteria: energy efficiency, sustainability, and operational efficiency. Various metrics were tracked to gauge the system's performance, including energy consumption, emission reductions, system responsiveness, and predictive accuracy. The data collected was analyzed both quantitatively and qualitatively to validate the system's efficacy in achieving the stated objectives.

3.1 Energy efficiency

The implementation of the ICS led to a significant reduction in energy consumption. The comparative analysis showed a 15% reduction in energy usage over the evaluation period compared to the baseline data collected before the implementation. This reduction was primarily attributed to the system's ability to

optimize operations through real-time monitoring and predictive analytics.

Peak demand periods were efficiently managed with an 18% reduction in peak energy demand. This was achieved through the intelligent scheduling and load-shifting capabilities of the ICS, thereby reducing the strain on the local grid and lowering energy costs.



Fig. 4: Setup of the Control Box

3.2 Sustainability and Operational Efficiency

The ICS contributed to a notable reduction in greenhouse gas emissions by optimizing energy consumption and integrating renewable energy sources. The system facilitated a 30% reduction in CO₂ emissions, aligning with the facility's sustainability goals.

ML algorithms successfully identified potential system anomalies allowing for timely maintenance, which in turn reduced downtime by 15%. The predictive accuracy of the system was found to be 90%, significantly enhancing the operational efficiency of the facility. Moreover, the system's responsiveness to changing conditions improved dramatically with a 20% reduction in the response time to anomalies or changing operational conditions. This was attributed to the real-time monitoring and control facilitated by the SCADA and Digital Twin technologies. The SCADA system is depicted in Figure A3 in Appendix.

The integration of digital assistants, such as telegram bots and Google Home, and intuitive control panels simplified user interaction, making system management more user-friendly. The feedback from the operators indicated a higher level of satisfaction due to the ease of operation and the timely insights provided by the system.

In our system, XGBoost and Random Forest algorithms are central for predictive analytics, directly aligning to enhance energy efficiency and operational sustainability. XGBoost's gradient boosting is crucial for efficiently processing large datasets to predict system failures or maintenance needs, thus contributing to reduced downtime and improved operational efficiency. The Random Forest algorithm complements this by effectively handling classification and regression tasks, crucial for predicting energy usage patterns and optimizing energy consumption. Additionally, the LSTM network is integrated for its proficiency in processing time-series data, crucial for forecasting future energy trends. This capability is vital for aligning energy supply with operational demands, thus bolstering our system's efficiency and sustainability.

4 Discussion

Our study's results reveal a significant leap in energy management within industrial settings, underscored by substantial gains in energy efficiency, sustainability, and operational performance. The integration of SCADA, ML, and Digital Twin technologies, particularly the effective use of XGBoost, Random Forest, and LSTM algorithms, was key to achieving these outcomes. This system not only reduced energy consumption and emissions but also enhanced the use of renewable energy sources, showcasing a practical approach to eco-friendly industrial practices. The predictive maintenance capabilities, powered by advanced ML algorithms, significantly reduced downtime, demonstrating the system's operational superiority. Our findings contribute to the evolving field of intelligent energy systems, offering a novel approach that blends traditional industrial control with cutting-edge digital

technologies. This synergy, as evidenced in a real-world industrial setting, presents a scalable model for future applications, potentially transforming energy management practices across various sectors.

5 Conclusion

Our study showcases a novel ICS framework combining SCADA, ML, and Digital Twin technologies, significantly improving energy efficiency, sustainability, and operational efficiency in a mid-scale industrial setting. Key achievements include a 15% reduction in energy consumption, an 18% reduction in peak energy demand, a 30% reduction in CO₂ emissions, and a 20% increase in renewable energy utilization. The system's ML algorithms enhanced predictive maintenance, leading to a 15% reduction in downtime and increased operational efficiency.

The communication backbone of our system played a crucial role in achieving seamless data transmission, which is vital for real-time monitoring and control across diverse industrial settings. This adaptability is achieved by integrating a range of communication protocols, each chosen for its specific benefits in different industrial contexts. For instance, OPC UA ensures secure and reliable data handling in sensitive areas, while Modbus TCP provides versatile connectivity between varied electronic units. RS-485's robustness makes it suitable for large-scale industrial environments, and Wi-Fi TCP/IP enables efficient remote system management.

Unlike other research focused solely on individual aspects of energy efficiency, predictive maintenance, real-time monitoring and control, and safety, [15], [16], [17], [18], our study combines these elements into a cohesive system. This approach not only enhances operational efficiency but also offers a more sustainable, scalable solution for energy management. Our system's real-world application demonstrates its practical advantages over traditional methods, marking a significant contribution to the field.

Recognizing the study's limitations, such as the scope of industrial application and data

diversity, future work will aim to broaden the system's applicability and enhance its data analytical capabilities. We also plan to explore the integration of emerging technologies, such as advanced IoT applications and newer AI paradigms, to enrich our system. These future efforts are not just about system enhancement but are pivotal in contributing to the evolving narrative of sustainable and efficient energy management in diverse industrial landscapes.

References:

- [1] K. Sayed and H. A. Gabbar, "Chapter 18 - SCADA and smart energy grid control automation," in *Smart Energy Grid Engineering*, H. A. Gabbar, Ed., Academic Press, 2017, pp. 481–514. doi: 10.1016/B978-0-12-805343-0.00018-8.
- [2] J. Figueiredo and J. Sá da Costa, "A SCADA system for energy management in intelligent buildings," *Energy Build.*, vol. 49, pp. 85–98, Jun. 2012, doi: 10.1016/j.enbuild.2012.01.041.
- [3] M. Kermani, B. Adelmanesh, E. Shirdare, C. A. Sima, D. L. Carni, and L. Martirano, "Intelligent energy management based on SCADA system in a real Microgrid for smart building applications," *Renew. Energy*, vol. 171, pp. 1115–1127, Jun. 2021, doi: 10.1016/j.renene.2021.03.008.
- [4] A. V. Jha, B. Appasani, D. K. Gupta, S. Ramavath, and M. S. Khan, "Machine Learning and Deep Learning Approaches for Energy Management in Smart Grid 3.0," in *Smart Grid 3.0: Computational and Communication Technologies*, B. Appasani and N. Bizon, Eds., in *Power Systems*, Cham: Springer International Publishing, 2023, pp. 121–151. doi: 10.1007/978-3-031-38506-3_6.
- [5] M. Zekić-Sušac, S. Mitrović, and A. Has, "Machine learning based system for managing the energy efficiency of the public sector as an approach towards smart cities," *Int. J. Inf. Manag.*, vol. 58, p. 102074, Jun. 2021, doi: 10.1016/j.ijinfomgt.2020.102074.
- [6] W. Ahmed et al., "Machine Learning Based Energy Management Model for Smart Grid and Renewable Energy Districts," *IEEE Access*, vol. 8, pp. 185059–185078, 2020, doi: 10.1109/ACCESS.2020.3029943.
- [7] W. Yu, P. Patros, B. Young, E. Klinac, and T. G. Walmsley, "Energy digital twin technology for industrial energy management: Classification, challenges and future," *Renew. Sustain. Energy Rev.*, vol. 161, p. 112407, Jun. 2022, doi: 10.1016/j.rser.2022.112407.
- [8] C. Ghenai, L. A. Husein, M. Al Nahlawi, A. K. Hamid, and M. Bettayeb, "Recent trends of digital twin technologies in the energy sector: A comprehensive review," *Sustain. Energy Technol. Assess.*, vol. 54, p. 102837, Dec. 2022, doi: 10.1016/j.seta.2022.102837.
- [9] C. Brosinsky, R. Krebs, and D. Westermann, "Embedded Digital Twins in future energy management systems: paving the way for automated grid control," - *Autom.*, vol. 68, no. 9, pp. 750–764, Sep. 2020, doi: 10.1515/auto-2020-0086.
- [10] W. Strielkowski, G. Rausser, and E. Kuzmin, "Digital Revolution in the Energy Sector: Effects of Using Digital Twin Technology," in *Digital Transformation in Industry*, V. Kumar, J. Leng, V. Akberdina, and E. Kuzmin, Eds., in *Lecture Notes in Information Systems and Organisation*. Cham: Springer International Publishing, 2022, pp. 43–55. doi: 10.1007/978-3-030-94617-3_4.
- [11] M. Lamagna, D. Groppi, M. Majidi Nezhad, and G. Piras, "A comprehensive review on digital twins for smart energy management system," *Int. J. Energy Prod. Manag.*, vol. 6, pp. 323–334, Nov. 2021, doi: 10.2495/EQ-V6-N4-323-334.
- [12] S. Agostinelli, F. Cumo, G. Guidi, and C. Tomazzoli, "Cyber-Physical Systems Improving Building Energy Management: Digital Twin and Artificial Intelligence," *Energies*, vol. 14, p. 2338, Apr. 2021, doi: 10.3390/en14082338.
- [13] A. Shahzad, H. Chae, M. Lee, H. Lee, and G. Jeong, "A Way to Access SCADA System via Satellite Channel and its Relevant Security Trends," *Int. J. Comput. Appl. Math. Comput. Sci.*, vol. 2, pp. 1–4, Jun. 2022, doi: 10.37394/232028.2022.2.1.
- [14] L. Massel and A. Massel, "Smart Digital Twins as a Trend of Energy Systems Intellectualization in Russia," in *Proceedings of the Seventh International Scientific Conference "Intelligent Information Technologies for Industry" (ITI'23)*, S. Kovalev, I. Kotenko, and A. Sukhanov, Eds., in *Lecture Notes in Networks and Systems*. Cham: Springer Nature, Switzerland, 2023,

- pp. 334–346. doi: 10.1007/978-3-031-43792-2_32.
- [15] T. Abbasi, K. H. Lim, and K. S. Yam, “Predictive Maintenance of Oil and Gas Equipment using Recurrent Neural Network,” *IOP Conf. Ser. Mater. Sci. Eng.*, vol. 495, no. 1, p. 012067, Apr. 2019, doi: 10.1088/1757-899X/495/1/012067.
- [16] J. Li, Y. Guo, X. Zhang, and Z. Fu, “Using Hybrid Machine Learning Methods to Predict and Improve the Energy Consumption Efficiency in Oil and Gas Fields,” *Mob. Inf. Syst.*, vol. 2021, p. e5729630, Dec. 2021, doi: 10.1155/2021/5729630.
- [17] A. Eso and D. Omorogiuwa, “Real-Time Effective Monitoring and Control in Oil and Gas Industry Using SCADA Technology as a Management Tool,” *J. Altern. Renew. Energy Sources*, vol. 8, pp. 22–38, Jul. 2022, doi: 10.46610/JOARES.2022.v08i02.004.
- [18] L. Zhang and J. Wang, “Intelligent safe operation and maintenance of oil and gas production systems: Connotations and key technologies,” *Nat. Gas Ind. B*, vol. 10, no. 3, pp. 293–303, Jun. 2023, doi: 10.1016/j.ngib.2023.05.006.

APPENDIX




Fig. A1: Architecture of the system




Fig. A2: Integrated communication and control architecture for intelligent energy management




Fig. A3: SCADA system

Contribution of Individual Authors to the Creation of a Scientific Article (Ghostwriting Policy)

The authors equally contributed in the present research, at all stages from the formulation of the problem to the final findings and solution.

Sources of Funding for Research Presented in a Scientific Article or Scientific Article Itself

This research was funded by a grant from the Ministry of Education and Science of the Republic of Kazakhstan BR18574136 "Development of deep learning and intellectual analysis methods for solving complex problems of mechanics and robotics" (2022-2024).

Conflict of Interest

The authors have no conflicts of interest to declare.

Creative Commons Attribution License 4.0 (Attribution 4.0 International, CC BY 4.0)

This article is published under the terms of the Creative Commons Attribution License 4.0

https://creativecommons.org/licenses/by/4.0/deed.en_US